



SIMA LABS

Sophisticated Industrial Materials
Analytic Labs Pvt. Ltd.

(GOVT. APPROVED TESTING LABORATORIES)

Address : A-3/7, Mayapuri Industrial Area,
Ph-II, New Delhi - 110064

Phone : +(91)-(011) 43854300

Email : reports@simalab.com

CIN No : U74899DL1988PTC031785

Website : www.simalab.net | www.simalab.com



TEST REPORT

Party Code : W//19804
*Issued to Wani's Nursing Home

Mominabad, Distt.-Anantnag, Jammu & Kashmir . -

*Sample Name : Effluent Water (ETP-Inlet)

REPORT NO. : SN0510001624
*Customer Ref.No. : NS
*Reference Date : NS
Date of Sampling : 07/05/2024
Date of Received : 10/05/2024
Date of Issue : 18/05/2024
Start Date of Analysis : 10/05/2024
Date of Completion : 18/05/2024
Environmental Condition : 25±2°C,RH 50±15%
Sample Condition : OK
*Sample Qty. : 1 Ltr.
SOP/Sampling Plan : SIMA/ENV/SOP/024
Test Method Deviation : NA
Sample Collection : Sample Drawn By Us

RESULTS OF ANALYSIS

Reference : EP Act Standards

Sample Description : One Effluent Water sample from Inlet of ETP was drawn by us on 07/05/2024

S.No.	Test Parameters	Units	Results	Method
Chemical Parameter				
1.	pH	NA	7.08	IS:3025 (P-11)
2.	Total Suspended Solids	mg/L	142	IS:3025 (P-17)
3.	Chemical Oxygen Demand	mg/L	480	IS:3025 (P-58)
4.	Biochemical Oxygen Demand (3 days at 27°C)	mg/L	210	IS:3025 (P-44)
5.	Oil & Grease	mg/L	6.4	IS:3025 (P-39)

NA- Not Applicable

Note :- Customer asked for the above tests only.

--- End of Test Report ---

Pinky Rai
Reviewed By

Authorized Signatory

Diwakar Jha
D.G.M Technical Environment

- Remarks:
- This Test Report is not valid without a hologram.
 - The Results listed refer only to the above tested sample & applicable parameters. Endorsement of products is neither inferred nor implied.
 - Liability of laboratory is limited to the invoiced amount only. Any dispute arising out of this report shall be subject to Delhi jurisdiction only.
 - This Test Report is not to be reproduced wholly or in part as evidence in the Court of law without written permission from SIMA Labs Pvt. Ltd.
 - The Test Report should not be used wholly or in part in any advertising media without written permission from SIMA Labs Pvt. Ltd.
 - The sample(s) of Drugs & Cosmetics will be destroyed after one year, Perishable samples (Other than Drugs & Cosmetics) will be destroyed after 7 days and non perishable samples will be destroyed after 30 days of the date of issue of Test Report or unless otherwise specified.
 - SIMA Labs Pvt. Ltd. will not be held responsible for the authenticity of any photocopied, forged and or partially presented test reports.
 - SIMA Labs Pvt. Ltd. will ensure all corrective action as per our policy in case of any discrepancy in any sample tested by SIMA Labs Pvt. Ltd.
 - Re-testing charges will be applicable in case the results are reproducible.
 - Duplicable copy will be issued on chargeable basis.
 - SIMA Stands for : Sophisticated Industrial Materials Analytic

Page : 1 of 1

VS

* Indicates details provided by the customer



SIMA LABS

Sophisticated Industrial Materials
Analytic Labs Pvt. Ltd.

(GOVT. APPROVED TESTING LABORATORIES)

Address : A-3/7, Mayapuri Industrial Area,
Ph-II, New Delhi - 110064

Phone : +(91)-(011) 43854300

Email : reports@simalab.com

CIN No : U74899DL1988PTC031785

Website : www.simalab.net | www.simalab.com



TEST REPORT

Party Code : W//19804
*Issued to : Wani's Nursing Home

Mominabad, Distt.-Anantnag, Jammu & Kashmir . -

*Sample Name : Effluent Water (ETP-Outlet)

REPORT NO. : SN0510001724
*Customer Ref.No. : NS
*Reference Date : NS
Date of Sampling : 07/05/2024
Date of Received : 10/05/2024
Date of Issue : 18/05/2024
Start Date of Analysis : 10/05/2024
Date of Completion : 18/05/2024
Environmental Condition : 25±2°C,RH 50±15%
Sample Condition : OK
*Sample Qty. : 1 Ltr.
SOP/Sampling Plan : SIMA/ENV/SOP/024
Test Method Deviation : NA
Sample Collection : Sample Drawn By Us

RESULTS OF ANALYSIS

Reference : EP Act Standards

Sample Description : One Effluent Water sample from Outlet of ETP was drawn by us on 07/05/2024

S.No.	Test Parameters	Units	Results	Limits	Method
Chemical Parameter					
1.	pH	NA	7.21	5.5 to 9.0	IS:3025 (P-11)
2.	Total Suspended Solids	mg/L	42	100	IS:3025 (P-17)
3.	Chemical Oxygen Demand	mg/L	120	250	IS:3025 (P-58)
4.	Biochemical Oxygen Demand (3 days at 27°C)	mg/L	21	30	IS:3025 (P-44)
5.	Oil & Grease	mg/L	<3.0	10	IS:3025 (P-39)

NA- Not Applicable

Note :- Customer asked for the above tests only. The above tested parameters meets the requirement of EP Act Standard.

--- End of Test Report ---

Pinky Rai
Reviewed By

Authorized Signatory

Diwakar Jha
D.G.M Technical Environment

- Remarks:
1. This Test Report is not valid without a hologram.
 2. The Results listed refer only to the above tested sample & applicable parameters. Endorsement of products is neither inferred nor implied.
 3. Liability of laboratory is limited to the invoiced amount only. Any dispute arising out of this report shall be subject to Delhi jurisdiction only.
 4. This Test Report is not to be reproduced wholly or in part as evidence in the Court of law without written permission from SIMA Labs Pvt. Ltd.
 5. The Test Report should not be used wholly or in part in any advertising media without written permission from SIMA Labs Pvt. Ltd.
 6. The sample(s) of Drugs & Cosmetics will be destroyed after one year, Perishable samples (Other than Drugs & Cosmetics) will be destroyed after 7 days and non perishable samples will be destroyed after 30 days of the date of issue of Test Report or unless otherwise specified.
 7. SIMA Labs Pvt. Ltd. will not be held responsible for the authenticity of any photocopied, forged and or partially presented test reports.
 8. SIMA Labs Pvt. Ltd. will ensure all corrective action as per our policy in case of any discrepancy in any sample tested by SIMA Labs Pvt. Ltd.
 9. Re-testing charges will be applicable in case the results are reproducible.
 10. Duplicable copy will be issued on chargeable basis.
 11. SIMA Stands for : Sophisticated Industrial Materials Analytic

Page : 1 of 1

VS

* Indicates details provided by the customer



Sophisticated Industrial Materials Analytic Labs. Pvt. Ltd.

GOVT. APPROVED TESTING LABORATORY

TAX INVOICE

(Issued Under Section 31 of GST Act, 2017)

Original/Duplicate

Code : W/19804 M/s. : Wani's Nursing Home Mominabad, Distt.-Anantnag, Jammu & Kashmir . - State Name : JAMMU & KASHMIR State Code : 01 GSTIN/UIN : - PAN : - Kind Att. : Contact Details :	Invoice No. : SIMA/24-25/0935 Invoice Date : 13/05/2024 P.O. No. : Place of Supply/Service : JAMMU & KASHMIR
--	---

Sl.	Sample Particulars	Report No.	Date	Amount
1	Effluent Water (ETP-Inlet)	SN0510001624	10/05/2024	4237.25
2	Effluent Water (ETP-Outlet)	SN0510001724	10/05/2024	4237.25
BANK DETAILS : Beneficiary Name : Sophisticated Industrial Materials Analytic Labs. Pvt. Ltd. Bank Name & Address : Canara Bank, Diplomatic Enclave, Malcha Marg, New Delhi - 110 021 Bank A/c No. : 0157256010031 IFSC / RTGS Code : CNRB0000157 Swift Code : CNRBINBDDFS E-MAIL Id. : lab_accounts@simalab.com Tax Is Payable On Reverse Charge : No		Amount		8474.50
(IN WORDS): Rs. TEN THOUSAND ONLY		Total		8474.50
		CGST @0.00%		0.00
		SGST @0.00%		0.00
		IGST @18.00%		1525.41
		Rounded Off		0.09
			Grand Total	10000.00

PAN : AAACS1068D
GSTIN : 07AAACS1068D1ZQ
Service Code (SAC) : 00998346
CIN : U74899DL1988PTC031785
Certified that the Particulars given above are true and correct.
E. & O. E.

For SOPHISTICATED INDUSTRIAL MATERIALS ANALYTIC LAB PVT LTD

Authorised Signatory

NOTE : WE ARE REGISTERED UNDER MSME ACT-2006 VIDE UAM NO: DL11B0003577

admin / MR. SHIV HARI SHARMA

